



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 11/7/09

Code 62.6.2-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3905.3.2		Page 695
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>E3905.3.2 Securing to box.</b> All permitted wiring methods shall be secured to the boxes. Exception: Where nonmetallic-sheathed cable <u>or multi-conductor Type UF</u> is used with boxes not larger than a nominal size of 2 1/4 inches by 4 inches (57mm by 102mm) mounted in walls or ceilings, and where the cable is fastened within 8 inches (203 mm) of the box measured along the sheath, and where the sheath extends through a cable knockout not less than 1/4 inch (6.4 mm), securing the cable to the box shall not be required. <u>Multiple cable entries shall be permitted in a single cable knockout opening.</u></p>		
REASON AND FISCAL IMPACT		
Type UF cable is permitted to be used in place of Type NM cable as indicated in Table E3801.4. This is brought forward from the 2005 IRC.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		